

**DECLARATION OF CONFORMITY**  
**№ DC-FP9000-EN/2017**

**Manufacturer:**                    *„DMTech” Ltd.*  
**Address:**                         *16, Nikolay Haytov Str..*  
*5800 Pleven, Bulgaria*

**DECLARES THAT:**

**The Products’ Description:**

*Conventional fire alarm panel FP9000-4, FP9000-8, FP9000L-2, FP9000L-4,FP9000L-6, FP9000L-8*

**With the unique identification codes:**

**FP9000-4, FP9000-8 and FP9000L-2, FP9000L-4,FP9000L-6, FP9000L-8**

**Meet/Comply to/ the following standards:**

*EN 54-2:1997*  
*EN 54-2:1997/A1:2006*  
*EN 54-2:1997/AC:1999*  
*EN 54-4:1997*  
*EN 54-4:1997/A1:2002*  
*EN 54-4:1997/A2:2006*  
*EN 54-4:1997AC:1999*

**The following Regulation:** *305/2011/EU*

**Notified Body:**                *NB1922, „DEDAL – A&C” Ltd.*

**Certificate:**                    *1922 -CPR -0844 of 18/04/2017 issued by „DEDAL – A&C ” Ltd.*



Signature: 

*Milen Kirov*  
*General Manager*  
*“DMTech” Ltd.*  
*18/04/2017*