

 Tel./fax
 : +359 64 801597

 e-mail
 office@dm-teh.com

 web
 : office@dmtech-ltd.com

 Address
 : Pleven, Bulgaria

DECLARATION OF PERFORMANCE

№ D9000A MCP/2019

According to Construction Products Regulation № 305/2011 EU

1. Identification code of the product type:

D9000A MCP

2. Number type:

D9000A MCP

Description: Manual call point

3. Intended use or uses of the construction product in accordance with the applicable harmonized specifications, as provided by the manufacturer.

Fire alarm systems installed in buildings and around them.

4. Manufacturer "DMTech" Ltd.

16, Nikolay Haytov Str. Pleven 5806, Bulgaria

5. Commercial Company "DMTech" Ltd.

16, Nikolay Haytov Str. Pleven 5806, Bulgaria

6. Evaluation System System 1

7. Certifying Authority "DEDAL – A&C" Ltd.

50, Mladost, 8230 Nessebar, Bulgaria

tel: +359 209715012

Certifying Authority №: NB 1922

EU Certificate: 1922 - CPR - 1275 of 01/11/2019,

8. European Technical Assessment None issued

9. Declared performance:



| Tel./fax : +359 64 801597 | office@dm-teh.com | office@dmtech-ltd.com | web : www.dmtech-ltd.com |

Pleven, Bulgaria

Standard's point	Description	Performance
5.17.	Enclosure protection	Pass
4.3.2.	Alarm condition	Pass
4.4.	Indicators for Alarm condition	Pass
5.7.1.	Safety aspects	Pass
5.2.	Operational performance test	Pass
5.3.	Function test	Pass
4.2.	Marking and data	Pass
4.3.1	Normal condition	Pass
4.5.	Reset facility	Pass
4.6.	Test facility	Pass
4.7.2	Shape, dimensions and colors	Pass
4.7.3	Symbols and lettering	Pass
4.7.5	Environment category	Pass
5.4.	Test facility test (operational)	Pass
5.5.	Reliability test (endurance)	Pass
5.7.	Dry heat (operational)	Pass
5.8.	Dry heat (endurance)	Pass
5.7.	Cold (operational)	Pass
5.10.	Damp heat, cyclic (operational)	Pass
5.12.	Damp heat, steady state (endurance)	Pass
5.13.	Sulphur dioxide (SO2) corrosion (endurance)	Pass
5.14.	Shock (operational)	Pass
5.15.	Impact (operational)	Pass
5.16	Vibration, sinusoidal (operational)	Pass
5.17	Vibration, sinusoidal (endurance)	Pass
5.6.	Vibration of supply parameters	Pass

10. The presentation of the products, referred to in (1) and (2), correspond to the declared performance in (9).

11. With this declaration of conformity is declared and the product's compliance with the requirements of the following additional standard:

EN 50130-4:2011,EN 55022:2006/A1:2007,EN 60950-1:2006/A11:2009

This declaration of performance is issued under the sole responsibility of the producer, referred to in (4).

Signature:

Milen Kirov General Manager DMTech Ltd. 01/11/2019

