

Tel./fax : +359 64 801597 e-mail : office@dm-teh.com : office@dmtech-ltd.com web : www.dmtech-ltd.com Address : Pleven, Bulgaria

## **DECLARATION OF PERFORMANCE**

#### № D9000MCP/2017

## According to Construction Products Regulation № 305/2011 EU

1. Identification code of the product type:

# **D9000MCP**

2. Number type:

# **D9000MCP**

### Description: Manual call point

3. Intended use or uses of the construction product in accordance with the applicable harmonized specifications, as provided by the manufacturer.

### Fire alarm systems installed in buildings and around them.

4. Manufacturer

5. Commercial Company

6. Evaluation System

7. Certifying Authority

Pleven 5806, Bulgaria

"DMTech" Ltd. 16, Nikolay Haytov Str.

"DMTech" Ltd. 16, Nikolay Haytov Str. Pleven 5806, Bulgaria

System 1

"DEDAL – A&C" Ltd. 50, Mladost, 8230 Nessebar, Bulgaria tel: +359 209715012

Certifying Authority  $\mathcal{N}_{2}$ :

EU Certificate:

8. European Technical Assessment

9. Declared performance:

1922 - CPR - 0943 of 06/12/2017,

None issued

**NB 1922** 

EN 54-11:2001, EN 54-3:2001/A1:2005 Fire alarm systems, Part 11 Manual call points.



 Tel./fax
 : +359 64 801597

 e-mail
 office@dm-teh.com

 web
 : www.dmtech-ltd.com

 Address
 : Pleven, Bulgaria

Standard's point	Description	Performance
5.17.	Enclosure protection	Pass
4.3.2.	Alarm condition	Pass
4.4.	Indicators for Alarm condition	Pass
5.7.1.	Safety aspects	Pass
5.2.	Operational performance test	Pass
5.3.	Function test	Pass
4.2.	Marking and data	Pass
4.3.1	Normal condition	Pass
4.5.	Reset facility	Pass
4.6.	Test facility	Pass
4.7.2	Shape, dimensions and colors	Pass
4.7.3	Symbols and lettering	Pass
4.7.5	Environment category	Pass
5.4.	Test facility test (operational)	Pass
5.5.	Reliability test (endurance)	Pass
5.7.	Dry heat (operational)	Pass
5.8.	Dry heat (endurance)	Pass
5.7.	Cold (operational)	Pass
5.10.	Damp heat, cyclic (operational)	Pass
5.12.	Damp heat, steady state (endurance)	Pass
5.13.	Sulphur dioxide (SO2) corrosion (endurance)	Pass
5.14.	Shock (operational)	Pass
5.15.	Impact (operational)	Pass
5.16	Vibration, sinusoidal (operational)	Pass
5.17	Vibration, sinusoidal (endurance)	Pass
5.6.	Vibration of supply parameters	Pass

10. The presentation of the products, referred to in (1) and (2), correspond to the declared performance in (9).

11. With this declaration of conformity is declared and the product's compliance with the requirements of the following additional standard:

EN 50130-4:2011,EN 55022:2006/A1:2007,EN 60950-1:2006/A11:2009

This declaration of performance is issued under the sole responsibility of the producer, referred to in (4).

Signature:

Milen Kirov General Manager DMTech Ltd. 06/12/2017



Page 2 of 2