

5806 Pleven, Bulgaria 58, Kliment Ohridski Str. Web: www.dmtech-ltd.com E-mail: office@dmtech-ltd.com

Made in EU

DECLARATION OF PERFORMANCE

№ D9000MCP/2022

According to Construction Products Regulation № 305/2011 EU

1. Identification code of the product type:

D9000MCP

2. Number type:

D9000MCP

Description: Manual call point

3. Intended use or uses of the construction product in accordance with the applicable harmonized specifications, as provided by the manufacturer.

Fire alarm systems installed in buildings and around them.

4. Manufacturer "DMTech" Ltd.

58, Kliment Ohridski Str. Pleven 5806, Bulgaria

5. Commercial Company "DMTech" Ltd.

58, Kliment Ohridski Str. Pleven 5806, Bulgaria

6. Evaluation System System 1

7. Certifying Authority "DEDAL – A&C" Ltd.

50, Mladost, 8230 Nessebar, Bulgaria

tel: +359 209715012

Certifying Authority №: NB 1922

EU Certificate: 1922 - CPR - 1812 of 22/06/2022,

8. European Technical Assessment None issued

9. Declared performance:

EN 54-11:2001, EN 54-3:2001/A1:2005 Fire alarm systems, Part 11 Manual call points.





5806 Pleven, Bulgaria 58, Kliment Ohridski Str.

58, Kliment Ohridski Str.
Web: www.dmtech-ltd.com
E-mail: office@dmtech-ltd.com

ISO 14001:2015 ISO 9001:2015 Certified Company

Made in EU

Standard's point	Description	Performance
5.17.	Enclosure protection	Pass
4.3.2.	Alarm condition	Pass
4.4.	Indicators for Alarm condition	Pass
5.7.1.	Safety aspects	Pass
5.2.	Operational performance test	Pass
5.3.	Function test	Pass
4.2.	Marking and data	Pass
4.3.1	Normal condition	Pass
4.5.	Reset facility	Pass
4.6.	Test facility	Pass
4.7.2	Shape, dimensions and colors	Pass
4.7.3	Symbols and lettering	Pass
4.7.5	Environment category	Pass
5.4.	Test facility test (operational)	Pass
5.5.	Reliability test (endurance)	Pass
5.7.	Dry heat (operational)	Pass
5.8.	Dry heat (endurance)	Pass
5.7.	Cold (operational)	Pass
5.10.	Damp heat, cyclic (operational)	Pass
5.12.	Damp heat, steady state (endurance)	Pass
5.13.	Sulphur dioxide (SO2) corrosion (endurance)	Pass
5.14.	Shock (operational)	Pass
5.15.	Impact (operational)	Pass
5.16	Vibration, sinusoidal (operational)	Pass
5.17	Vibration, sinusoidal (endurance)	Pass
5.6.	Vibration of supply parameters	Pass

10. The presentation of the products, referred to in (1) and (2), correspond to the declared performance in (9).

11. With this declaration of conformity is declared and the product's compliance with the requirements of the following additional standard:

EN 50130-4:2011,EN 55022:2006/A1:2007,EN 60950-1:2006/A11:2009

This declaration of performance is issued under the sole responsibility of the producer, referred to in (4).

Signature: &

Milen Kirov General Manager DMTech Ltd. 22/06/2022