

CERTIFICATE

№ 0580

Issued by Product Certification Body "Dedal- Attestation and Certification" Ltd.

Fire detection and fire alarm systems. Addressable fire alarm panel FP9000A

(For list of compatible products, see Annex I to Certificate № 0580 that is an inseparable part of this certificate)

placed on the market under the name or trade mark of
DMTech Ltd.

1 Ekzarh Yosif Str., 5800 Pleven, Bulgaria

and produced in the manufacturing plant of
DMTech Ltd.

58 Kliment Ohridski Str., 5803 Pleven, Bulgaria

This certificate attests that the construction product complies with standard

EN 54-13:2017+A1:2019

according to certification scheme type 7 and that the products fulfil all the prescribed requirements set out above.

This certificate was first issued as on 15.07.2025 and will remain valid as long as the test methods and/or factory production control requirements defined in standard EN 54-13:2017+A1:2019 and used to assess the conformity of the declared characteristics, do not change, and the product, and the manufacturing conditions in the plant are not modified significantly. The validity of the issued certificate is supported through annual surveillance audits. The validity of this certificate can be verified in the register on www.dedal-bg.net



Manager:

Anna Vasileva


dipl. eng. Anna Vasileva

Place: Burgas
Date: 15 July 2025

Ref. No. 01-00

ANNEX I TO CERTIFICATE № 0580/15.07.2025 (Page 1/1)

Model	Description	Certificate
Control and indicating equipment		
FP9000A	Addressable fire alarm panel	1922-CPR-1802
Smoke detectors		
D9000A SR	Addressable Optical Smoke Detector	1922-CPR-1811
Heat detectors- point detectors		
D9000A T A1R	Addressable heat detector	1922-CPR-1809
D9000A T A1S	Addressable heat detector	1922-CPR-1809
Combined smoked and heat detectors		
D9000A MSR A1R	Addressable Combined-Optical Smoke and Heat Fire Detector	1922-CPR-1808
Manual Call Points		
D9000A MCP	Addressable Manual call point with short circuit isolator	1922-CPR-1813
Fire alarm devices		
S9000	Conventional Sounder	1922-CPR-1804
S9000AF	Addressable sounder with short circuit isolator	1922-CPR-1805
Input/output devices		
M9000A IO	Addressable single-input and single-output device with Short-circuit isolator	1922-CPR-1814
M9000A ACZ	Addressable Input/output device with short-circuit isolator controlling a conventional fire alarm line	1922-CPR-1814
Devices type 2		
FP9000A R	Addressable repeater	-



Manager: 
dipl. eng. Anna Vasileva